

PROVINCIAL GOVERNMENT OF DAVAO DE ORO

Cabidianan, Nabunturan, Davao de Oro

TECHNICAL SPECIFICATIONS FORM

Purchase Request Number: 24-5288

| Bid Number: | B-24-0303 | | | | |
|-------------|------------|--|--|--|--|
| Date: | 10/29/2024 | | | | |
| Page: | 1 of 2 | | | | |

| ITEM NO. | QTY. | UNIT OF ISSUE | DESCRIPTION | APPROVED BUDGET | | BID PRICES | |
|-------------|------|------------------|--|----------------------------|------------------------------|------------|-------------|
| | | | | Unit Price | Total Amount | Unit Price | Total Amour |
| | | | Supply and Installation: Generator Set, 750 KVA - 800 KVA, Silent Type TERMS & CONDITION: 1. Supply and installation of the Generator set shall commence only upon receipt of Notice to Proceed. Inquire to the building custodian as to the specific area of installation. 2. The supplier shall provide and install a generator set, complete with all necessary accessories, at the site specified. Also, all equipment and materials needed in the implementation shall be provided by the supplier. 3.The supplier warrants that the generator set | Unit Price 7,200,000.00 | Total Amount 7,200,000.00 | Unit Price | Total Amoun |
| | | | will be free from defects in materials, accessories, engines, other components, and workmanship for a period of 24 months or 2000 running hours (whichever comes first) from the date of commissioning. 4. Maintenance of the newly installed generator set will be covered by the contractor for 24 months 5. The generator set must be complete with all necessary accessories and parts, such as engine, alternator, control panel, fuel tank, cooling system and other necessary components. Spare parts package such as but not limited to, engine oil filter, air filter, fuel filter and spark plug | | | | |
| | | | 6. The supplier shall test and commission the generator set to ensure that it is operating correctly and safely. 7. The supplier shall provide training and/or orientation to the building custodian and personnel on the operation and maintenance of the generator set. | | | | |
| | | | The supplier shall provide a toolbox containing necessary tools for maintenance and repair of the generator set. | | | | |
| | | | | SUB-TOTAL | 7,200,000.00 | | |



PROVINCIAL GOVERNMENT OF DAVAO DE ORO

Cabidianan, Nabunturan, Davao de Oro

TECHNICAL SPECIFICATIONS FORM

Purchase Request Number: 24-5288

 Bid Number:
 B-24-0303

 Date:
 10/29/2024

 Page:
 2 of 2

| ITEM NO. | QTY. | UNIT OF ISSUE | DESCRIPTION | APPROVED BUDGET | | BID PRICES | |
|-------------|---------------------|------------------|---|-----------------|--------------|------------|--------------|
| | | | | Unit Price | Total Amount | Unit Price | Total Amount |
| | | | 9. Newly installed equipment and generator set components are held accountable by the contractor if damage due to natural hazards and/or by the workers under the contracting firm before the acceptance of the job order. 10. Calendar days to complete is 45 days. | | | | |
| | | | | GRAND TOTAL | 7,200,000.00 | | |
| | For the use PGSO | of Capitol I | Building. | | | | |
| - | f Delivery: 4 | 5 Days | | | | | |